



DAV UNIVERSITY

+91 - 181- 270 8844

Telephone

naac@davuniversity.org

E-mail

www.davuniversity.org

Website

7.1.2 The Institution has facilities for alternate sources of energy and energy conservation measures

Permission document for connecting to the grid from the Government/ Electricity authority


S. No.	Program	Page No.
1.	Periodic AC Energy Report for the Solar Power Plants installed at DAV University	<u>1</u>
2.	PEDA approval for wheeling to the grid	<u>2</u>
3.	Electricity Bill showing the solar energy wheeled to the grid	<u>4</u>

Periodic AC Energy Report for Site D A V UNIVERSITY

Report Period: From 01/01/2019 to 04/10/2024
Location: Sarmastpur, India
Peak Power: 100 kWp
Installation Date: 02/12/2019
Revenue calculation: No revenue calculation

Inverter	Serial Number	AC Energy()
Inverter 1	7E149DC9-F8	81904.49
Inverter 2	7E149DC8-F7	93845.77
Inverter 3	7E149E25-55	88493.29
Inverter 4	7E14AE23-63	92606.69
Total for site		356850.24

ATTESTED


Registrar
DAV University, Jalandhar

Letter of Approval

To

Mr. / Ms/M/s DAYANAND ANGLO VEDIC COLLEGE AND MANAGEMENT SOCIETY
A/c No J64BS1200006.

Memo No.: 1422

Date: 18-5-18

Ref:

Your request of RID No PEDA20184108337.1

Your request for installing Rooftop PV system for 100 kW capacity is considered and approval is accorded with the following conditions:-

1. You shall set up the plant and submit the work completion report along with Single Line Diagram of the synchronizing and protection arrangements issued by the plant supplier/EPC contractor duly approved by PEDA that the plant has been installed as per standards and specifications within 180 days . In the case of delay you shall have to get further extensions from PSPCL Such extension will be granted for a maximum period of 2-months only and the approval granted will lapse automatically If the project is not set -up even in the extended 2- months period. However ,you will be eligible to apply in the next financial year but your application will be kept at the bottom of the list of applicants and you will be permitted to set-up the plant only if all the applicants above you are selected and there is still capacity available for allotment.
2. You will abide by the guidelines on net metering for Grid Interactive Rooftopsolar Photo voltaic Power Plants issued by Govt. of Punjab /PSEERC/PSPCL
3. The solar plant shall comply with the relevant standards specified by the MINRE/BIS and CEA. The responsibility of operation and maintenance of the solar photovoltaic (SPV) generator including all accessories and apparatus lies with the consumer. The design and installation of the rooftop SPV should be equipped with appropriately rated protective devices to sense any abnormality in the system and carry out automatic isolation of the SPV from the grid . The inverters used should meet the necessary quality requirements and should be certified for their quality by appropriate authority : the protection logics should be tested before commissioning of the plants.
4. The automatic isolation or islanding protection of SPV should be ensured for ,no grid supply and low or over voltage conditions and within the required response time .Adequate rated fuses and fast acting circuit breakers on input and output side of the inverters and disconnect/isolating switches to isolate DC and AC system for maintenance shall be provided . The consumer should provide for all internal safety and protective mechanism for earthing ,surge . DC ground fault ,transients etc.

ATTESTED
Registrar
DAV University, Jalandhar

To prevent back feeding and possible accidents when maintenance works are carried out by PSPCL personal, Double pole / Triple pole with isolating disconnecting switches which ever applicable can be locked by PSPCL personnel should be provided. This is in addition to automatic sensing and isolating on grid supply failure etc and in addition to internal disconnecting switches. In the event of PSPCL LT/HT supply failure , the consumer has to ensure that there will not be any solar power being fed to the LT/HT grid of PSPCL. You will be solely responsible for any accident to human beings/animals whatsoever (fatal/non fatal/departmental/non departmental) that may occur due to back feeding from the SPV plant when the grid supply is off. PSPCL have the right to disconnect the rooftop solar system at any time in the event of possible threat/damage, from such rooftop solar system to its distribution system ,to prevent any accident or damage, without any notice.

You shall abide by all the codes and regulations issued by the Commission to the extent applicable and in force from time to time and shall comply with PSERC/PSPCL/CEA power injected into the grid shall be of the required quality in respect of wave shape , frequency absence of DC components etc.

The inverter standard shall be such that it should not allow solar power/battery power to extend to PSPCL's Grid on failure of PSPCL's grid supply irrespective of connectivity options.

You shall restrict the harmonic generation within the limit specified in IEEE 519 or as may be specified by the Central Electricity Authority.

*Connected Load KW/KVA (980KW/990KVA)
Capacity of Proposed SPV IN 100 KW.*

Recommended.

ਸਰਕਾਰੀ ਇੰਜੀਨੀਅਰ
ਪੰਜਾਬ ਰਾਜ ਪਾਵਰ ਆਰਪੀਏਡਲ ਲਿਮ.
ਮੁਖ-ਤਿਹਾਸ਼ੀਲ ਅਰਾਵਲਪੁਰ ਜਲੰਧਰ !

APPROVED

ADDL S.E./DS
East Divn.
P:SP.C. Ltd. Jalandhar

AE/AEE/XEN/DS

Sub Division.....

PSPCL.....

ATTESTED

Registrar
DAV University, Jalandhar

ATTESTED

Registrar
DAV University, Jalandhar

Print Bill


PUNJAB STATE POWER CORPORATION LIMITED										Billing Category			
(Regd. Office P.S.E.B. Head Office, The Mall Patiala-147001, Ph. 1912), CIN: U40109PB2010SGC033813										BS HT BULK SUPPLY DPC			
E-mail: 1912@pspcil.in, Website: www.pspcl.in, GSTIN NO: 03AAFCP5120Q1ZC													
Original for Recipient Duplicate for Supplier, Taxable Invoice, Invoice-cum-Bill of Supply													
Sub Division	Division	Circle	Bill Cycle	Bill Date	Bill No.								
ALAWALPUR JALANDHAR	EAST DIVISION JALAND	JALANDHAR	07-2023	27-JUL-2023	1005815753								
A/C No.: 300550326 Consumer Name: M/S REGIONAL DIRECTOR C/O DAV INST OF E Address: SARMASTPUR JALANDHAR ALAWALPUR-144301-INDIA GST No.: Connection Date: 05-02-2018 Mobile No.: 99XXXXX921			Load	Contract Demand	Tariff Type	Bill Status	Due Date		Bill Amount				
			980.00	990.00	BS HT BULK SUPPLY DPC	0	11-Aug-2023	09-Aug-2023	Rs.1055900/-				
			Voltage Supply	Details of Meter				Meter Status	CT Make	CT No.			
			11.00	Meter Number	Make	Capacity	Digit	0	123				
Feeder Code		Date of New Reading	Date of Old Reading	Bill Period	Meter Security	Securit Cons.	Security cons/Meter Security Interest						
FDC0000004699		27-JUL-2023	26-JUN-2023	31	33750	1529617							
Meter Reading													
Details	Old Reading	New Reading	Current Units	Meter Multiplier	Line CT Ratio	Meter CT Ratio	Overall Multiplier	MMTS Correction	Old Meter Cons.	Unit Consumed			
KWH	356859.00	365376.00		1.00	50/5	5/5	10.00			85170			
KVAH	361662.00	370247.00		1.00	50/5	5/5	10.00			85850			
MDI	49.4	23.96		1.00	50/5	5/5	10.00			239.6			
(A) Fixed Charges													
Contract Demand (L) KVA		Actual Demand KVA (A)		80% of (L) KVA (B)		A or B whichever greater KVA (C)		Rate per KVA per month (R)		Billing Days (D)	A: Fixed Charges Amount = CxRxDx12/365		
990.00		239.6		792.00		792.00		340.00		31	274444.00		
(B) Energy Charges													
			Units		Rate/kWh		Amount		B: Total Energy Charges				
0-100			0				0.00		582063				
100-300			0				0.00						
300-500			0				0.00						
500 & ABOVE			0				0.00						
(C) Fuel Cost Adjustment Charges													
Total Energy Charges		KVAH Consumption		Rate of FCS/KVAH		C: Amount		Unit		Rate	Amount	C: FCA + Addl Surcharges	
582063						0.00					0.00	582063	
(D) Rental Charges													
Meter Rent for PSPCL Meter		MCB, CT/PT Unit Rental		Rent for any other equipment		Total Rent		HSN Code		SGST	CGST	Total GST	D: Total Rent with Tax
2532		0				2532				227.68	227.68	455.76	2987.76
(E) Surcharges													
Voltage Surcharge				Demand Surcharge			ToD Surcharge				E: Total Surcharge (Rs.)		
Supply Voltage	Catered Voltage	Surcharge Rate	Voltage Surcharge Amount	Demand in excess	Rate of Demand Surcharge	Amount of Demand Surcharge	Peak Hours KVAH	Rate	Amount				
11.00	11.00			0.00	0.00	0.00	10460.00	2.00	20920.00	20920.00			
(F) Rebates													
Voltage Rebates					ToD Rebates						F: Total Rebates (Rs.)		
Units		HT/EHT Rebate		Amount		Non-Peak Hours KVAH		Amount					
0.00		0.00		0.00		0.00		0.00		0.00			

ATTESTED
 Registrar
 DAV University, Jalandhar

Solar Meter	Solar	KWH	484943	484981	1.00	9962
		KVAH	497339	482205	1.00	15134
		KVA	71.18	0	1.00	71
Previous Carry Forward: 0	Net Consumption:	Net Cons. for Billing:	Total Consumption: 0		Current Carry Forward: 0	
Solar Installation Date: 0		Solar Capacity:	Import Amount (at retail tariff):		Export Amount (at feed-in tariff): 0	

Powered by O/o CE(IT) PSPCL

Print Date: 10-19-2023 01:59 PM

ATTESTED

 Registrar
 DAV University, Jalandhar

ATTESTED

 Registrar
 DAV University, Jalandhar